

# Norwegian Tax Authority - Oslo Norway

Arne Førland-Larsen






# Environmental goals

## Initially energy label B

Goals were increases to Energy label A and:

- Meeting passive house criteria
- Meeting Future Built criteria
- Meeting criteria to be granted by ENOVA
- Fulfilling criteria BREEAM – “Very Good”



# Overcoming user skeptical to passive house

Will it be hot during summertimes ?  
Will it be cold during wintertime ?



# Indoor temperature summer before and after

	Existing	Refurbish	
Temperatur above 26 °C [h]	14	0	Hours
Temperatur over 25 °C [h]	274	0	Timer
Temperatur over 24 °C [h]	670	159	Timer
Temperatur over 23 °C [h]	1042	831	Timer
Temperatur over 22 °C [h]	2505	2470	Timer
Temperatur over 21 °C [h]	2895	2920	Timer
Temperatur over 20 °C [h]	2920	2920	Timer
Maks sommer temperatur	26,5	24,5	°C

Glazing area in proportion to internal area of outerwall increases from ~25 % to ca. ~45%



**Daylight factor of 2 (from facade)**


**New ~ 3 – 3,5 m**

**Existing ~ 2 – 2,5 m**

**Mean daylight factor**

**New ~2,5**

**Existing ~2,0 m**



# Adjusting client brief

- Demand for 500 LUX in all areas – **7 W/m<sup>2</sup>**
- Alerted to 300 lux general light level, and 500 lux on workplace – **5 W/m<sup>2</sup>**



# Adjusting internal loads equipment


- Internal load computers where measured
- Present % where discussed / adjusted
- Working hours discussed / adjusted

## **Reversed internal premises in brief**

- PC "Thin Clients" 120 W pr. pc – 100% load
- Person 80 % present percentage during working hours
- Working hours 8.00 – 16.00

# OVERALL DESIGN STRATEGY

- Optimizing the building envelope
- Optimizing technical system
- Utilization / recovery of energy from data facility in the building




Reduced envelope to volume ratio  
and avoid "cooling fingers"

# Optimizing glazing



# Optimizing the building envelope


- Roof construction: U-value:  $< 0,13 \text{ W/m}^2\text{K}$  (average)
- Wall construction : U-value:  $< 0,14 \text{ W/m}^2 \text{ K}$  (average above ground)  
U-value:  $< 0,47 \text{ W/m}^2 \text{ K}$  (average below ground)
- Windows: : U-value:  $< 0,72 \text{ W/m}^2 \text{ K}$  (average)
- Thermal bridge avoidance, wood facade construction with few thermal bridges., and 200 mm insulation in front of slabs.
- Overall demand to thermal bridges are:  $< 0,02 \text{ W/m}^2 \text{ K}$
- Airtightness n50-value  $< 0,6 \text{ h}^{-1}$




On site made construction


On site made construction

Prefabricated construction






# Embodied Energy – CO<sub>2</sub> reduction



# The basement – optimal solution ?


Heated areas      Unheated areas



Economical payback time  
CO<sub>2</sub> payback time

~ 45 year  
~ 6 year

# Air tightness measurement – 5 test



# Technical solutions

## LIGHTING SYSTEM

- LENI number ~15 kWh/m<sup>2</sup> year

## HEATING SYSTEM

- Water based heating systems, based on heat recovery from data facilities in basement

## COOLING

- Reduced cooling demand

## VENTILATION Efficient ventilations system

- VAV mechanical ventilation
- Efficient heat recovery – 85 % in average
- Low SFP < 1,5 kW/ m<sup>3</sup> /s

# Estimate for reel budget – Further improvements / reductions – focus on el consumption !

Energy budget Frederik Selmersvei	Existing building	Energy refurbished building				Energy reduction
	Electircity	Electricity	Heating	Total		
	kWh/ m <sup>2</sup> år	kWh/ m <sup>2</sup> år	kWh/ m <sup>2</sup> år	kWh/ m <sup>2</sup> år	kWh/ m <sup>2</sup> år	
Space Heating	57 <sup>2)</sup>	3 <sup>3)</sup>	5 <sup>5)</sup>	7 <sup>3)</sup>	50	
Mech. Vent. Heating	23 <sup>2)</sup>	1 <sup>3)</sup>	2 <sup>5)</sup>	3 <sup>3)</sup>	20	
Domestic hot water	5 <sup>2)</sup>	1 <sup>3)</sup>	2 <sup>5)</sup>	3 <sup>3)</sup>	2	
Mech. Vent fans	15 <sup>2)</sup>	12		12	3	
Pumps	1 <sup>2)</sup>	2		2	-1	
Lighting	32 <sup>2)</sup>	16		16	16	
Technical equipment, PC, data	40 <sup>2)</sup>	40		40	0	
Cooling, beams and vetilation	4 <sup>2)</sup>	6		6	-3	
Kitchen - process	8 <sup>2)</sup>	8 <sup>2)</sup>		8	0	
Elevators	2 <sup>2)</sup>	2 <sup>2)</sup>		2	0	
Outsite light	1 <sup>2)</sup>	1 <sup>2)</sup>		1	0	
El power other tech. Systems	3 <sup>2)</sup>	3 <sup>2)</sup>		3	0	
<b>Total energi consumption</b>	<b>190</b> <sup>1)</sup>	<b>95</b>	<b>8</b>	<b>103</b> <sup>4)</sup>	<b>87</b>	

Electricity  
consumption  
~ 90 %

Heat  
consumption  
~ 10 %

Measure	Description	Amount	Unit	Extra	Energy saving	Energy saving	Energy saving	Payback
				investment	Energy saving	Energy saving	Energy saving	time
				[Euro]	[kWh/ year]	[kWh/ m2 year]	[euro/ year]	[year]
<b>Building envelope:</b>								
Walls above ground	U- value improved from 0,3 in average to 0,15 W/m2 K	14 500	m <sup>2</sup>	1 680 000	249 375	7,1	31 172	54
Walls below ground	U-value improved from 0,47 in average to 0,37 W/m2 K (basement are 4,5 m below ground level in average)	1 500	m <sup>2</sup>	80 000	13 125	0,4	1 641	49
Roof	U- value improve from 0,22 in average to 0,13 W/m2 K	4 480	m <sup>2</sup>	110 000	61 250	1,7	7 656	14
Roof basement	Roof in basement below ground level (facing ground), from 1,0 to 0,15 W/m2 K	2 800	m <sup>2</sup>	130 000	476 875	13,6	59 609	2
Air tight building	Air tightness improve from 1,5 to 0,6 h <sup>-1</sup> (n <sub>50</sub> value)	132 000	m <sup>3</sup>	125 000	271 250	7,7	33 906	4
			(volume building)					
Passive house windows	U-value improved from 1,2 i average to 0,8 W/m2 K	3 500	m <sup>2</sup>	350 000	118 125	3,4	14 766	24
Cold bridges	Improved from 0,15 to 0,03 W/m2 K	35 000	m <sup>2</sup>	50 000	91 875	12,6	11 484	4
Floor facing outside above the ground	U- value improved from 0,22 in average to 0,13 W/m2 K	450	m <sup>2</sup>	70 000	7 000	0,2	875	80
<b>Technical system and energy supply</b>								
Heat recovery and VAV mechanical vent.	Heat recovery on mechanical ventilation improved from 70% to 85% in average, and demand controlled VAV mechanical ventilation.	240 000	m <sup>3</sup> /h	240 000	843 500	24,1	105 438	2
SFP	Specific fanpower reduced from 2,0 to 1,5 kW/ m3/s in average	240 000	m <sup>3</sup> /h	120 000	122 500	3,5	15 313	8
Efficient lighting	Efficiency of lighting system improved from LENI 25 to 12,4 kWh/m2 year	35 000	m <sup>2</sup>	840 000	420 000	12,0	52 500	12
Energy supply	System for heatrecovery from data facility in basement (water based heating system not included)	35 000	m <sup>2</sup>	100 000	560 000	16,0	70 000	1
<b>Process planning quality ensurance</b>								
	Extra project planning cost, quality planning etc., course workers on site.	35 000	m <sup>2</sup>	170 000	-	-	-	-
<b>Overall budget investments cost</b>				<b>4 065 000</b>	<b>3 234 875</b>	<b>102</b>	<b>404 359</b>	<b>10</b>
<b>Subsidized</b>				<b>2 400 000</b>				
<b>Pay back time with subsidizing</b>				<b>1 665 000</b>				<b>4,1</b>

**Building envelope  
– long pay back time**

**Technical systems  
– “short” pay back time**

**Average  
– “short” pay back time**

# Summing up - Conclusion

- Pay back time for measures on building envelope are in general long
- Pay back time for technical measures are in general “reasonable” / short
- Refurbishment to passive house level is possible with a “reasonable” pay back time for the entire solution
- Improving of existing basements is a challenge
- Measures for reduction of power consumption has in general large potentials
- The design and technical solutions are in general well know technology.
- Daylight has to be emphasized in the design process
- Discuss demands in client brief

