

## 1. INTRODUCTION

### PROJECT SUMMARY

- *Year of construction – 1972*

### SPECIAL FEATURES

- *Building retrofitting methodology through calibrated building energy modeling, to meet NABERS 4 star rating scheme. Three orders of decisions were developed:*
- i. Control of internal loads,*
  - ii. Control of Environmental loads,*
  - iii. HVAC improvements.*

### ARCHITECTS

*Prof. Richard Hyde, Indrika Rajapaksha, Upendra Rajapaksha and Ken Yeang.*

### ENGINEERS

*Nathan Groenhout  
Francis Barram*

### OWNER

*Investa*

## 160 Ann Street, Brisbane, Australia



Brochure: R. Hyde, U. Rajapaksha, I. Rajapaksha.  
Contact: [richard.hyde@sydney.edu.au](mailto:richard.hyde@sydney.edu.au)

### IEA – SHC Task 47

Renovation of Non-Residential Buildings towards Sustainable Standards

## 2. CONTEXT AND BACKGROUND

### BACKGROUND




- Building is located in the CBD of Brisbane Australia, in a warm sub-tropical climate, approx. 27° S, densely populated with medium to high rise buildings adjacent to Brisbane river.
- It is a 23-storey tower with NLA: 15,877m<sup>2</sup>; 820m<sup>2</sup> each floor, being internal load dominant.
- Whole building energy rating is between 2 – 2.5 stars.
- Total energy consumption is 270 Kwh/m<sup>2</sup>/a
- Tenants and HVAC are 126 and 147 KWh/m<sup>2</sup>.annum

### OBJECTIVES OF THE RENOVATION


- Meet Queensland Emission reduction targets, energy performance improvements to accomplish:
  - 4 stars NABERS rating of 182 KWh/m<sup>2</sup>.annum operational energy foot print for the whole building

### SUMMARY OF THE RENOVATION

- Step 1 - Internal load controls – using non-technological & technological strategies
- Step 2 - Environmental load controls – using technological strategies
- Step 3 - System improvements – using non-technological & Technological strategies to upgrade the HVAC system




Typical Office floor –  
Level 4 – Level 21



### 3. DECISION MAKING PROCESSES

- Project initiated by Prof. Richard Hyde at University of Queensland under research named “Exploring Synergies with Innovative Green Technologies: Redefining Bioclimatic Principles for Multi Residential Buildings and Offices in Hot and Moderate Climates”.
- This building was considered as a “Critical Case” representing common physical and operational characteristics of typical high rise office buildings in Australia.
- Public funding program: ARC (Australia Research Council)



## 4. BUILDING ENVELOPE

**Roof construction** : U-value: 2.3W/m<sup>2</sup>.K  
 Materials . (Interior to exterior)  
 RCC concrete (existing) 250 mm  
 Pure Bitumen (existing) 20 mm  
 Total (existing) 285 mm

**Wall construction** : U-value: 2.7W/m<sup>2</sup>.K  
 Materials . (Interior to exterior):


**Slab construction** : U-value: 3.0W/m<sup>2</sup>.K  
 Materials . (Interior to exterior):

**Windows** : U-value: 2.63 W/m<sup>2</sup>.K  
 Double-glazing (existing)  
 Clear glass 6 mm  
 Cavity with venetian blinds 50 mm  
 Bronze tinted glass 6 mm

**Thermal bridge avoidance:**  
 Airtightness (existing) 1.0ach/h  
 Airtightness (new) 0.5ach/h  
 0.11ach/h??

### Summary of U-values [W/m<sup>2</sup>K]

	Before	After (1)	After (3)
Floor/slab	3.0		1.3
Walls	2.7	0.565	0.143
Roof	2.3		0.095
Windows	2.63		0.76



## 5. BUILDING SERVICES SYSTEM

### OVERALL DESIGN STRATEGY

#### STEP 1 (FIRST ORDER)

Controls to internal heat loads

- Before (CCIM) 273 KWh/m<sup>2</sup>/a
- After 163 KWh/m<sup>2</sup>/a

#### LIGHTING SYSTEM

Reduction of power density load

- Before 12 W/m<sup>2</sup>
- After 9 W/m<sup>2</sup>

#### STEP 2 (SECOND ORDER)

Controls environmental heat loads

- Before 163 KWh/m<sup>2</sup>/a
- After 155 KWh/m<sup>2</sup>/a

#### VENTILATION/ INFILTRATION

- Before 1.0ach.h
- After 0.5ach.h

#### INSULATION (see page 4)

#### STEP 3

HVAC improvements

- Before 155 KWh/m<sup>2</sup>/a
- After 111 KWh/m<sup>2</sup>/a


#### HVAC SYSTEM

- Before COP 2.5
- After COP 5.0

#### INTERNAL TEMPERATURE

#### SETPOINT

- Before 21.5°C
- After 24°C



## 6. ENERGY PERFORMANCES

### Queensland Emission reduction targets

- 4 star energy efficiency rating for commercial buildings by 2010
- Carbon neutral government office buildings by 2020

### Retrofit scenarios satisfies the 2010 emission reduction targets

- 1383713 KWh per annum, 87 KWh/m<sup>2</sup>.annum
- By 2020 – 3.9% increase in energy usage due to climate change.
- Green Power requirement (Whole building)
  - 1437768 KWh per annum
  - 90 KWh/m<sup>2</sup>/annum

### To achieve near carbon neutral status

- Green power to move from improved energy efficiency status to near carbon neutral status (Step 4 )

### For internal load control

#### Using technological and non-technological interventions

- Scenario 1 FSM + Operational and occupancy profile – for BCA only
- Scenario 2 (1) + Efficient appliances (plug loads) – for BCA, PH and ASHRAE
- Scenario 3 (02) + Lighting – for BCA, PH and ASHRAE
- Scenario 3A (03) + Daylight linear off sensors for artificial light – for BCA, PH and ASHRAE
- Scenario 3B (03A) + Window blinds operation with solar sensors – for BCA, PH and ASHRAE

### For internal load + environmental load control

#### Using technological interventions

- Scenario 4 (03B) + Infiltration – for BCA, PH and ASHRAE
  - Scenario 5 (04) + Insulation to external walls – for BCA, PH and ASHRAE
  - Scenario 6 (05) + Insulation to total opaque surfaces – for BCA, PH and ASHRAE
  - Scenario 7 (06) + Solar transmission control to glazing – for BCA, PH and ASHRAE
  - Scenario 8 (07) + Efficient HVAC (increased COP 5) – for BCA, PH and ASHRAE (Summer)
- 
- Scenario 8A (08) + Increase of set point temperature by 1 degree C – no heating
  - Scenario 9 (08A) + Mixed mode HVAC system (winter no heating)
- 
- Scenario 10 (10A) + increase of glazing in envelope
  - Scenario 11 Scenario 11 for climate change effects 2030
  - Scenario 12 (11) + Green power, PV Cells – for BCA, PH and ASHRAE

## Conceptual thermal behaviour appraisal

## 7. ENERGY PERFORMANCE

Items that could be covered:

### Modeling methodology

- input data collection
- Model development
- Simulation
- Calibration
- Retrofit solution/sets

### Simulation Program

Dynamic energy simulation software:

- Design Builder version 2.2.5
- G.U.I. for EnergyPlus simulation engine.


Model development involved the following;

- Critical Case Input Model – CCIM
- Forward Simulation Model - FSM
- Model calibration


### Building Design Characteristics

- Externalities (building design and microclimate)
- Internalities (occupancy, equipment and systems)


Both affect the heat load profiles and therefore energy performance were the **AREAS** for retrofitting.



Operational energy consumption – 61.3% (HVAC + Lighting)



Total energy usage



% of energy saving

## 8. MORE INFORMATIONS

### RENOVATION COSTS

- Specified for individual energy saving measure and expected pay back time if possible
- To achieve a 65% energy cuts in existing buildings, require an economic analysis to justify the retrofitting decisions.

### FINANCING MODEL

- Subsidized loans:
- Grants:
- Interest level: Public disclosure
- Public incentives: Government tenancy require 4.5 star
- ESCO contracts: N/A
- Market conditions:

### OTHER INTERESTING ASPECTS

Potential for ecological integration

### REFERENCES

Hyde et al, Sustainable Retrofitting, 2012, Chapter 2.4 & 2.5

### Energy efficiency scenarios that PASS the economic test

SC	Scenario descriptions	Approach 1 Payback (years)	Approach 2 NPV ( \$ )
SC-1	Occupancy and operational profile of BCA	-	506.681
SC-2	SC-2a Efficient appliances	0,1	967.392
	SC-2b Increase cooling set-point temperature by 1 degree	0,3	187.769
	SC-2c Advance computer managemente systeme	1,1	881.708
SC-3	Infiltration improvements	2,8	15.577
SC-6	Low emission transmission; double glazing	1,4	63.617
SC-7	Efficient Lighting	-	1.645.415
SC-9	Efficient chiller system	0,8	488.163
	Mixed mode HVAC system with winter no heating	1,7	272.786
SC-10	Mechanical services (Pumps and lifts)	0,5	722.622
SC-12	HVAC Fans & VAV diffuser system	6,2	791.830

### Energy efficiency scenarios that FAIL the economic test

SC	Scenario descriptions	Approach 1 Payback (years)	Approach 2 NPV ( \$ )
SC-4	Insulate external walls	44	91.054
SC-5	Insulate total opaque surfaces	2.971	10.264.638
SC-8	SC-8a Daylight linear off sensors	26	12.675
SC-8	SC-8b Window blinds operation with sensors	19	8.691